

IAPMO RESEARCH AND TESTING, INC.

5001 East Philadelphia Street, Ontario, California 91761-2816 – USA • 909-472-4100 • 909-472-4244 • www.iapmort.org



CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body which tests and inspects samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Effective Date: August 2019

Void After: August 2024

Product: Internal Pipe Epoxy Coating

File No. 4491

Issued To: Curaflo Ip Llc
Curaflo Bc
7436 Fraser Park Dr
Burnaby, BC V515B9
Canada

Identification: Internally coated pipe shall be marked on outside with the manufacturer's name or registered trademark, coating designation and material, prohibition on the use or heat and flame to repair any part of the system, and the UPC® certification mark. Markings shall be applied at each outlet and at twenty foot intervals of exposed piping. Epoxy containers shall bear the following markings, affixed by label: Manufacturer's name or trademark, "Certified to IAPMO IGC 189" and "Certified to ASTM F2831".

Characteristics: A mechanically applied epoxy coating material to pressurized metallic and non-metallic piping systems. The coating shall be applied in accordance with the manufacturer's instructions and the latest edition of the Uniform Plumbing Code.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.


Chairman, Product Certification Committee


CEO, The IAPMO Group



This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.



IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING

Void After: August 2024

Product: Internal Pipe Epoxy Coating

File No. 4491

Issued To: Curaflo Ip Llc

Products are in compliance with the following code(s):

Uniform Plumbing Code (UPC®)

International Plumbing Code (IPC®)

Products are in compliance with the following standard(s):

IAPMO IGC 189-2008 (R2014) and ASTM F2831-2012



IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Void After: August 2024

Product: Internal Pipe Epoxy Coating

File No. 4491

Issued To: Curaflo Ip Llc

MODELS:

Note: This product shall not be used where section 310.2 of the Uniform Plumbing Code is violated.

Curapoxy

Curapoxy LS